




2025 CHC Project Review

Richard Williams
Cube Hydro Carolinas, LLC


Streamflow 2025

- Q1 inflow avg 74% of median
 - Q2 inflow avg 86% of median
 - Q3 inflow (thru Sept 15th) avg 100% of median
-
- Expected mean avg for 2025 = 4,323 cfs. (20-year average)
 - Actual daily avg for 2025 (thru Sept 15th) = 3,713 cfs (86% of Expected)


QTR 1 High Rock Rule Comparison




QTR 2 High Rock Rule Comparison



QTR 3 High Rock Rule Comparison



2025 High Rock Lake Rule Comparison



2025 Summary

- CHC Yadkin project has not entered low inflow protocol in 2025.
- CHC Yadkin has not had a rule curve deviation in 2025.
- Fish spawn enhancement period completed within spawning limits.
- No violations of the daily minimum streamflow.
- Project gross generation output in 2025 is ~92% of projection.
- Current Elevation data is available on our web-site. Search Lake Levels – Cube Hydro Carolinas

Questions??

Richard Williams

Richard.williams@eaglecreekre.com